



TREMCO CPG MALAYSIA
Report No. TR 2210-1354

Cleanroom[®] Suitable Materials

Flowseal EPW Wall
Outgassing VOC / SVOC
ISO-ACC_m Class -7.1 / < -9.6

FLOORING & COATING

Single product
Outgassing Behavior
VOC/SVOC

Qualification Certificate

We hereby certify that the material stated above, provided by

TREMCO CPG MALAYSIA SDN BHD
Kuala Lumpur, Malaysia

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2210-1354.

The outgassing behavior of Flowseal EPW Wall (color: off white) at the stated temperatures was investigated according to VDI 2083 Part 17 and ISO 14644-15. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding Contaminant Category:

Contaminant Category (x)	SER _a ¹⁾ 23 °C [g/m ² s]	SER _a ¹⁾ 90 °C [g/m ² s]	ISO-ACC _m Class (x) based on 23 °C
VOC	7.9×10^{-8}	Due to overload of the analytical system no quantitative result can be reported	-7.1
SVOC	$< 2.8 \times 10^{-10}$		< -9.6
Amines	$< 2.8 \times 10^{-10}$		--
Organophosphates	$< 2.8 \times 10^{-10}$		--
Siloxanes	$< 2.8 \times 10^{-10}$		--
Phthalates	$< 2.8 \times 10^{-10}$		--

¹⁾SER_a: Area-specific emission rate

FL 1607-836
Report No. first document
TR 2210-1354
Report No. current document

Stuttgart, October 18, 2016
Place, date of first document issued
Stuttgart, March 3, 2023
Place, current date

on behalf of 

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.