



TREMCO CPG MALAYSIA  
Report No. TR 2210-1354

# Cleanroom<sup>®</sup> Suitable Materials

Flowshield SL  
Biological Resistance: weak

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

**TREMCO CPG MALAYSIA SDN BHD**  
Kuala Lumpur, Malaysia

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2210-1354.


The biological resistance of Flowshield SL (color: light gray) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	2	weak
Procedure C (resistance to bacteria)	0	excellent
Overall result	weak	

The classification is based on a worst-case consideration of the Procedures A and C.

FL 1607-836  
Report No. first document  
TR 2210-1354  
Report No. current document

Stuttgart, October 18, 2016  
Place, date of first document issued  
Stuttgart, March 3, 2023  
Place, current date

on behalf of 

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.