



valid until: September 24, 2025

# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Thorn Lighting Ltd  
Duoproof 2  
**Report No. TH 2304-1419**

Product series  
**Particle Emission**

## Qualification Certificate

This is to certify that the product mentioned above, provided by

**Thorn Lighting Ltd**  
Durham, United Kingdom

has been awarded a Fraunhofer certificate TESTED DEVICE  
bearing the report number TH 2304-1419.

The luminaire series Thorn Duoproof 2 (color: white) was assessed  
in compliance with ISO 14644-14. When operated under the  
specified test conditions, it is suitable for use in cleanrooms  
fulfilling the specifications of the following Air Cleanliness Class  
according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	3
Overall result	

It should be noted that cleanrooms of Class 1 to 5 according to  
ISO 14644-1 have a higher filter occupancy, which may restrict  
the use of panel lighting systems. Cleanrooms with a horizontal  
displacement flow form an exception to this. The test result may  
be affected by the surrounding ceiling system.  
Please note: Transport damages, incorrect installation, aging  
behavior, corrosion etc. can influence the test result.

TH 2304-1419  
Report No. first document

Stuttgart, September 24, 2020  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of 

This document only  
applies to the named  
product in its original state  
and is valid for a period of  
5 years from the date the  
first document was issued.  
The document can be  
verified under  
**www.tested-device.com**.

Detailed information and  
parameters of the test  
environment can be found  
in the Fraunhofer IPA test  
report.



**Fraunhofer**  
IPA