



**Fraunhofer**

**TESTED<sup>®</sup>  
DEVICE**

Knauf Ceiling Solutions  
Armstrong Bioguard Acoustic  
**Report No. KN 2101-1202**

DUPLICATE

Statement of  
Qualification

Single product  
Particle Emission

Customer

Knauf Ceiling Solutions GmbH & Co. KG  
Elsenthal 15  
94481 Grafenau  
Germany

Component tested

Category: Cleanroom Facilities

Subcategory: Wall/Ceiling/Floor/Door

Product name: Armstrong Bioguard Acoustic 17 mm  
(manufacturing date: 11/9/2020; article number: BP2703;  
dimension: 600x600x17 mm)

Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines: ISO 14644-1, -14  
The norms stated generally refer to the version valid at the time of the tests.

Test devices: Optical particle counter:  
LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1\text{ }\mu\text{m}$ ,  $\geq 0.2\text{ }\mu\text{m}$ ,  
 $\geq 0.3\text{ }\mu\text{m}$ ,  $\geq 0.5\text{ }\mu\text{m}$ ,  $\geq 1.0\text{ }\mu\text{m}$  and  $\geq 5.0\text{ }\mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Temperature: .....22 °C  $\pm$  0.5 °C
- Relative humidity: ..... 45 %  $\pm$  5 %

Test procedure parameters: The ceiling system was subjected to stress as follows:

- Structure-borne noise: .....approx. 5 to 50 Hz
- Oscillation velocity ( $\varnothing$ ):.....v = 0.7068 mm/s
- Oscillation acceleration ( $\varnothing$ ):.....a = 0.0192 m/s<sup>2</sup>
- Deflection of the system ( $\varnothing$ ):.....s = 0.1350 mm

Test result / Classification

When operated under the specified test conditions, the ceiling system Arm-  
strong Bioguard Acoustic 17 mm is suitable for use in cleanrooms fulfilling  
the specifications of the following Air Cleanliness Class according to  
ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 5 to 50 Hz	3
Overall result	

It should be noted that cleanrooms of class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of ceiling systems. Cleanrooms with a horizontal displacement flow form an exception to this.

The test result may be affected by the surrounding ceiling system, in parti-  
cular the material pairing between lights and ceiling frames, as well as other  
mounting accessories. Particle emission behavior should be reassessed in each  
assembly situation.

Please note: Transport damages, incorrect installation, aging behavior,  
corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing  
Engineering and Automation IPA

Department of Ultraclean Technology  
and Micromanufacturing

Nobelstrasse 12  
70569 Stuttgart  
Germany

KN 2101-1202  
Report No. first document

Stuttgart, March 29, 2021  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of  
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA