



valid until: December 6, 2029

# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Parteco S.r.l.  
Parteco PST and CIS system  
**Report No. PA 2410-1571**

Single product  
Hygienic Design

## Qualification Certificate

This is to certify that the product mentioned above, provided by

**Parteco S.r.l.**  
Lissone, Italy

has been awarded a Fraunhofer certificate TESTED DEVICE  
bearing the report number PA 2410-1571.

The Parteco PST and CIS system (color ceiling panel: RAL9010) is  
principally suitable for use in hygienic areas up to the following  
GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class A / B

However, this only applies to the tested operating utility in a res-  
ting state. An overall reassessment would need to be made after  
installation in a manufacturing environment.

This document only  
applies to the named  
product in its original state  
and is valid for a period of  
5 years from the date the  
first document was issued.  
The document can be  
verified under  
[www.tested-device.com](http://www.tested-device.com).

Detailed information and  
parameters of the test  
environment can be found  
in the Fraunhofer IPA test  
report.

PA 2410-1571  
Report No. first document

Stuttgart, December 6, 2024  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA