



Fraunhofer

TESTED[®] DEVICE

Rite-Hite Corporation
LITESPEED CLEANROOM
Report No. RI 2108-1247

Single product Riboflavin Test (Equipment)

Qualification Certificate

This is to certify that the product mentioned above, provided by

**Rite-Hite Material Handling
Equipment (Kunshan) Co., Ltd.**
Kunshan Jiangsu , China

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number RI 2108-1247.

The LITESPEED CLEANROOM High Performance Door (color: white) can be cleaned well using a simple wiping procedure with ultra-pure water. However, the fluorescence test identified a few critical areas. It is extremely difficult to clean these areas of the door effectively.

These areas have to be cleaned especially thoroughly or using a more complex procedure, e.g. by removing certain parts before cleaning.

System component	Assessment of cleanability
LITESPEED CLEANROOM	good

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RI 2108-1247
Report No. first document

Stuttgart, March 3, 2022
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA