



valid until: January 30, 2031

# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Roxtec International AB  
SLFRS 200 HF MS RAL9016  
**Report No. RO 2601-1704**

### Single product Particle Emission in Cleanroom (atmospheric)

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**Roxtec International AB**  
Lyckeby, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RO 2601-1704.

The SLFRS 200 HF MS RAL9016 + RS 200 AISI316 WOC + GASKET SLFR/RS 200 SILICONE (color: RAL9016 (White)) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %), it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
<b>Overall result</b>	

Please note: Transport damages, incorrect installation, oil leakage; aging behavior, corrosion etc. can influence the test result.

RO 2601-1704  
Report No. first document

Stuttgart, January 30, 2026  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.