




IPA

Cleanroom (atmospheric)

valid until: January 30, 2031

Fraunhofer

TESTED[®] DEVICE

Roxtec International AB
SLFRS 200 HF AISI316 GB
Report No. RO 2601-1704

Single product
**Particle Emission
in Cleanroom
(atmospheric)**

Qualification Certificate

This is to certify that the product mentioned above, provided by

Roxtec International AB
Lyckeby, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number RO 2601-1704.

The SLFRS 200 HF AISI316 GLASS BLASTED + RS 200 AISI316
WOC + GASKET SLFR/RS 200 SILICONE (color: gray) was assessed
in compliance with ISO 14644-14. When operated under the
specified test conditions (room temperature: $22^{\circ}\text{C} \pm 0.5^{\circ}\text{C}$;
relative humidity: $45\% \pm 5\%$), it is suitable for use in cleanrooms
fulfilling the specifications of the following Air Cleanliness Class
according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
Overall result	

Please note: Transport damages, incorrect installation, oil leakage;
aging behavior, corrosion etc. can influence the test result.

RO 2601-1704
Report No. first document

Stuttgart, January 30, 2026
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.



Fraunhofer
IPA