



Fraunhofer

TESTED[®] DEVICE

Roxtec International AB
LABSEAL C LTX
Report No. RO 2508-1666

Single product
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

Roxtec International AB
Lyckeby, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number RO 2508-1666.

The LABSEAL C LTX WITH COUNTER FRAME 0-40 (color: white)
is principally suitable for use in hygienic areas up to the following
GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this only applies for the tested operating utility when
in a resting state and an overall reassessment would need to be
made after installation in a manufacturing environment.

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

RO 2508-1666
Report No. first document

Stuttgart, September 24, 2025
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA