



Gerflor
Report No. GE 2105-1233

Cleanroom[®] Suitable Materials

Mip. Biocontrol Clean
(slightly structured)
Riboflavin Test: weak

FLOORING & COATING

Single product Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

Gerflor Mipolam GmbH
Troisdorf, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2105-1233.

The examination of cleanability of Mipolam Biocontrol Clean (color: gray 5430) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
Mipolam Biocontrol Clean (slightly structured)	weak

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 2105-1233
Report No. first document
--
Report No. current document

Stuttgart, September 20, 2021
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA