

# Fraunhofer

# TESTED<sup>®</sup> DEVICE

igus GmbH E4Q.34.100.100.0 **Report No. IG 2401-1484** 

Statement of Qualification

Single product

Particle emission

Dry-Cleanroom





## **Statement of Qualification** • Single product

iaus GmbH Customer

Spicher Strasse 1a 51147 Cologne Germany

**Component tested** 

Category: **Energy Supply** 

Cable Guiding System Subcategory

e-chain E4Q.34.100.100.0 of the series E4Q.34 Product name:

(manufacturing date: 9/25/2023; color: black; article number:

E4Q.34.100.100.0; serial number: E4Q.34)

### Random sampling of particle emissions (airborne) at representative sites in the dry room

Standards/Guidelines:

ISO 14644-1, -14

The norms stated generally refer to the version valid at the time of the tests.

Test devices:

Optical particle counter:

LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1 \,\mu\text{m}$ ,  $\geq 0.2 \,\mu\text{m}$ ,  $\geq$  0.3  $\mu$ m,  $\geq$  0.5  $\mu$ m,  $\geq$  1.0  $\mu$ m and  $\geq$  5.0  $\mu$ m

Test environment parameters:

• Dry and clean environment with Class (according to ISO 14644-1):.... ISO 3

• Airflow pattern: displacement flow

• Temperature: ......21°C ± 1.5°C

• Humidity/Dew point: -40°C±2°C

Test procedure parameters:

• Stroke length: s = 820 mm • Parameter Set 1:.....v<sub>1</sub> = 0.5 m/s; a<sub>1</sub> = 1.0 m/s<sup>2</sup> • Parameter Set 2:  $v_2 = 1.0 \,\text{m/s}$ ;  $v_3 = 2.0 \,\text{m/s}^2$ • Parameter Set 3:  $v_2 = 2.0 \,\text{m/s}$ ;  $a_2 = 4.0 \,\text{m/s}^2$ 

### Test result/Classification

When operated under the specified test conditions, the energy chain E4Q.34.100.100.0 of the series E4Q.34 is suitable for use in cleanrooms (with a dew point of -40 °C  $\pm$  2 °C and room temperature of 22 °C  $\pm$  1 °C) fulfilling the specifications of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanlines Class
$v_1 = 0.5 \text{m/s};  a_1 = 1.0 \text{m/s}^2$	5
$v_2 = 1.0 \text{m/s};  a_2 = 2.0 \text{m/s}^2$	5
$v_3 = 2.0 \text{m/s};  a_3 = 4.0 \text{m/s}^2$	5
Overall result	5

Please note: Transport damages, incorrect installation, aging behavior, etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

Department of Ultraclean Technology and Micromanufacturing

Nobelstrasse 12 70569 Stuttgart Germany

IG 2401-1484 Report No. first document Stuttgart, March 15, 2024

Place, date of first document issued

Report No. current document Place, current date

on behalf of River

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Fraunhofer