



Sika Deutschland GmbH
Report No. SI 2501-1580

Cleanroom[®] Suitable Materials

Sikafloor BC 375 N AS
(smooth)
Riboflavin Test: excellent

FLOORING & COATING

Single product Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 2501-1580.

The examination of cleanability of Sikafloor BC 375 N AS (color: gray) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
Sikafloor BC 375 N AS (smooth)	excellent

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

SI 2501-1580
Report No. first document
--
Report No. current document

Stuttgart, September 24, 2025
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification