

nora systems GmbH Report No. NO 2302-1393

## R Cleanroom Suitable **Materials**

noraplan sentica ed (948) H<sub>2</sub>O<sub>2</sub> Absorption / Desorption: fast

## **FLOORING & COATING**

## Single product Hydrogen Peroxide Absorption/Desorption

## **Qualification Certificate**

We hereby certify that the material stated above, provided by

nora systems GmbH Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 2302-1393.

The hydrogen peroxide absorption/desorption of noraplan sentica ed (948) (color: 7052) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

| <b>Ø k-value</b><br>[min] | Standard deviation<br>[min] | Classification |
|---------------------------|-----------------------------|----------------|
| 6.01                      | 0.29                        | fast           |

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

NO 1711-969 Report No. first document NO 2302-1393 Report No. current document

**IPA** 

🗾 Fraunhofer

Stuttgart, February 28, 2018 Place, date of first document issued

Stuttgart, May 17, 2023

Place, current date on behalf of Dr.-Ing. Udo Gommel, Project Manager Fraunt