

nora systems GmbH Report No. NO 2302-1393

Cleanroom® Suitable Materials

norament 926 grano Biological Resistance: good

FLOORING & COATING

Single product Biological Resistance

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Qualification Certificate

We hereby certify that the material stated above, provided by

nora systems GmbH Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 2302-1393.

The biological resistance of norament 926 grano (color: 5319) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	1	good
Procedure C (resistance to bacteria)	0	excellent
Overall result	good	

The classification is based on a worst-case consideration of the Procedures A and C.

NO 1711-969 Report No. first document NO 2302-1393 Report No. current document Stuttgart, February 28, 2018 Place, date of first document issued

Stuttgart, May 17, 2023

Place, current date on behalf of Dr.-Ing. Udo Gommel, Project Manager Fraunt