



valid until: January 30, 2031

Fraunhofer

TESTED[®] DEVICE

Saint-Gobain Ecophon AB
Gedina A T24 NE 20 mm

Report No. SA 2511-1961

Single product
Electrical
Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Saint-Gobain Ecophon AB
Hyllinge, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number SA 2511-1691.

The ceiling panel Gedina A T24 NE 20 mm is not compliant with
the general requirements for ESD control items as per
DIN EN IEC 61340-5-1.

Measuring point	Operating voltage [V]	Max. mean value R_{p-p} [Ω]	Conformity assessment based on DIN EN IEC 61340-5-1
Point-to-point resistance (R_{p-p})	100	1.2×10^{12}	Non-compliant

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.

The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

SA 2511-1691
Report No. first document

Stuttgart, January 30, 2026
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of


Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA