



valid until: January 30, 2031

Fraunhofer

TESTED[®] DEVICE

Saint-Gobain Ecophon AB
OPTA E T24

Report No. SA 2511-1961

Single product
Electrical
Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Saint-Gobain Ecophon AB
Hyllinge, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number SA 2511-1691.

The ceiling panel OPTA E T24 shows limited compliance with general requirements for ESD control items as per DIN EN IEC 61340-5-1. Electrical resistance values in this range exceed the typical limits for dissipative surfaces defined in DIN EN IEC 61340-5-1. Therefore, the suitability as ESD control item depends on the specific implementation and may require a field control concept.

Measuring point	Operating voltage [V]	Max. Max. mean value R_{p-p} [Ω]	Conformity assessment based on DIN EN IEC 61340-5-1
Point-to-point resistance (R_{p-p})	100	1.9×10^{10}	Limited compliance

SA 2511-1691
Report No. first document

Stuttgart, January 30, 2026
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Burger, head of business unit Testing and Certification

DUPLICATED

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.