



valid until: October 2, 2030

Fraunhofer

TESTED[®] DEVICE

DYNACO EUROPE NV
Dynaco D-313 CR LF
Report No. DY 2508-1659

Single product
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

DYNACO EUROPE NV
Moorsel, Belgium

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number DY 2508-1659.

The door Dynaco Europe D-313 Cleanroom LF (color curtain:
white) is principally suitable for use in hygienic areas up to the
following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this only applies to the tested system in a resting state;
an overall assessment of the manufacturing environment would
need to be made after its installation.

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

DY 2508-1659
Report No. first document

Stuttgart, October 2, 2025
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA