



Fraunhofer

TESTED[®] DEVICE

Regiolux GmbH
ADAMP 1500 14200 DALI
Report No. RE 2404-1517

DUPLICATE

Statement of
Qualification

Single product
Particle Emission

Customer	Regiolux GmbH Hellinger Strasse 3 97486 Königsberg Germany
Component tested	
Category:	Cleanroom Facilities
Subcategory:	Lighting Systems
Product name:	ADAMP/340-1500 LED 14200 940 DALI IP65 (manufacturing date: 3/2024; color: traffic white; article number: 6215 4026 670; charge number: PO02)

Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines:	ISO 14644-1, -14 The norms stated generally refer to the version valid at the time of the tests.
Test devices:	Optical particle counter: LasAir II 110 and LasAir III 110 with measuring ranges $\geq 0.1\text{ }\mu\text{m}$, $\geq 0.2\text{ }\mu\text{m}$, $\geq 0.3\text{ }\mu\text{m}$, $\geq 0.5\text{ }\mu\text{m}$, $\geq 1.0\text{ }\mu\text{m}$ and $\geq 5.0\text{ }\mu\text{m}$
Test environment parameters:	<ul style="list-style-type: none">Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1Airflow velocity:.....0.45 m/sAirflow pattern:..... vertical laminar flowTemperature:22 °C \pm 0.5 °CRelative humidity: 45 % \pm 5 %
Test procedure parameters:	The luminaire was subjected to stress as follows: <ul style="list-style-type: none">Structure-borne noise: approx. 50 HzOscillation velocity (\varnothing):.....v = 7.2844 mm/sOscillation acceleration (\varnothing):.....a = 2.3016 m/s²Deflection of the system (\varnothing):..... s = 0.0815 mm

Test result / Classification

When operated under the specified test conditions, the luminaire ADAMP/340-1500 LED 14200 940 DALI IP65 is suitable for use in clean-rooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50 Hz	1
Overall result	

It should be noted that cleanrooms of class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of panel lighting systems. Cleanrooms with a horizontal displacement flow form an exception to this.

The test result may be affected by the surrounding ceiling system, in particular the material pairing between lights and ceiling frames, as well as other mounting accessories. Particle emission behavior should be reassessed in each assembly situation.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA	RE 2404-1517 Report No. first document	Stuttgart, June 12, 2024 Place, date of first document issued
Department of Ultraclean Technology and Micromanufacturing	-- Report No. current document	-- Place, current date
Nobelstrasse 12 70569 Stuttgart Germany	on behalf of Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA	