



valid until: August 5, 2030

Fraunhofer

TESTED[®] DEVICE

Fagerhults Belysning AB
Multilume Hydro G3 600x600
Report No. FA 2507-1642

Single product
Particle Emission
in Cleanroom
(atmospheric)

Qualification Certificate

This is to certify that the product mentioned above, provided by

Fagerhults Belysning AB
Habo, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number FA 2507-1642.

The luminaire Multilume Hydro G3 600x600 (color: white) was
assessed in compliance with ISO 14644-14. When operated under
the specified test conditions (room temperature: $22^{\circ}\text{C} \pm 0.5^{\circ}\text{C}$;
relative humidity: $45\% \pm 5\%$), it is suitable for use in cleanrooms
fulfilling the specifications of the following Air Cleanliness Class
according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise: $f = \text{approx. } 50\text{ Hz}$	1
Overall result	

It must be pointed out, that according to ISO 14644-1 cleanrooms
classes 1 to 5 have a high filter occupancy, with the result that
large-surface lighting/ceiling systems cannot be used in some
cases. Cleanrooms with a horizontal displacement flow form an
exception to this.

Please note: Transport damages, incorrect installation, aging
behavior, corrosion etc. can influence the test result.

FA 2507-1642
Report No. first document

Stuttgart, August 5, 2025
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.



Fraunhofer
IPA