



Forbo-Novilon B.V.  
Report No. FO 2303-1409

# Cleanroom<sup>®</sup> Suitable Materials

ONYX IMPACT

Chemical Resistance: very good

## FLOORING & COATING

### Single product Chemical Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

Forbo-Novilon B.V.  
KA Coevorden, The Netherlands

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FO 2303-1409.

The chemical resistance tests on Onyx Impact wall covering (color: K005-8611) are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083 Part 17 have been transferred to the following classification:

Chemicals	Chemical resistance	Chemicals	Chemical resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochlorid acid 5 %	excellent
Isopropanol 100 %	very weak	Hydrogen peroxide 30 %	excellent
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	very weak	Sodium hypochlorite 5 %	excellent
Overall result	very good		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

FO 2303-1409  
Report No. first document  
--  
Report No. current document

Stuttgart, April 6, 2023  
Place, date of first document issued  
--  
Place, current date

on behalf of 