



valid until: June 19, 2031

Fraunhofer

TESTED[®] DEVICE

Glamox AS
C61

Report No. GL 2604-1769

Product series
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

Glamox Sp. z o.o.
Dobczyce, Poland

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number GL 2604-1769.

The luminaire series C61 (color: white) is principally suitable for
use in hygienic areas up to the following GMP Class according to
EU GMP Annex 1:

Suitability
up to GMP Class C

However, this only applies to the tested system in a resting state;
an overall assessment of the manufacturing environment would
need to be made after its installation.

The device may only be used in GMP Class A or B when it is cer-
tain that the geometry of the large-surface lamp does not impair
the quality of the laminar flow.

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

The norms stated generally
refer to the version valid at
the time of the tests.

GL 2604-1769
Report No. first document

--
Report No. current document

Stuttgart, June 19, 2026
Place, date of first document issued

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification